

**Guangzhou Testing & Inspection Institute
for Household Electrical Appliances**
204, Xingang West Road, Guangzhou, 510300, P. R. China
http://www.gtihea.com, E-mail: goffice@gtihea.com
Tel: 0086-20-84462287, Fax: 0086-20-84183160



GTIHEA

Certificate of Compliance

No.LVD07-2226

**About the Low Voltage Directive 73/23/EEC
as last amended by EEC Directive 93/68/EEC**

The applicant:

Guangzhou Sinro (Fogang) Controls Co., Ltd.
Xuetian, Longshan Town, Fogang County, Guangdong Province, 511685, P. R. China.

has successfully demonstrated that its:

Product : Liquid Flow Switch
Trade Mark : SINRO
Model/Type : LK01A, LK01B
Rated Specification: AC250V, 10(3)A, Type 1, IP64, 10000 cycles
is complied with: EN60730-1:2000+A11:2002+A12:2003+A13:2004+A14:2005
+A1:2004; EN60730-2-18:2000+A11:2005

Referred to the Technical Report: RZCE2006-0757LVD

This certificate of conformity is based on an evaluation of a tested sample of the product mentioned above. It does not imply assessment of series-production of the product. The applicant should hold the whole technical report at the disposal of the competent authority.

Provided it is also confirmed with any other EU directives, the manufacturer or its authorized European representative may draw up an EC/EEA Declaration of Conformity and affix the CE-mark shown below to each conforming product.



i. a. Zhu Can
Zhang Xuxing
Vice Director of GTIHEA
Date of Issue: Jan. 17, 2007